

























DRAWING NOTES

- 1
- Relamp existing F32T8 luminaire(s) with F32T8 25W lamps, (refer to bed specifications).
- 2
- New 4 lamp F32T8 25W tandem, Low Bay Indust. Strip (refer to bid specifications).
- 4
- Relamp with CFL, (refer to bid specifications)
- 5
- No change to existing luminaire or lamps(s)
- 6
- Install new LED EXIT SIGN
- 8
- Convert existing T12 lamp(s) to T8 lamp(s).
- 9
- Convert existing 4 lamp F32T8 luminaire to 2 lamp F32T8 25W luminaire, (refer to bid specifications).
- 10
- Install new 2 lamp F32T8 25W surface mount luminaire, (refer to bid specifications).
- 11
- Luminaire not in use
- 12
- Relamp F32T8 U-tube with F32T8 25W U-tube

LUMINAIRE SCHEDULE					
CALLOUT	SYMBOL	LUMINAIRE	DESCRIPTION	MOUNTING	WATTS
A		1 LAMP F25T8	STRIP LIGHT, (3-FOOT)	UNDER CABINET	22
A1e		1 LAMP F32T8 25W	STRIP LIGHT, (4-FOOT)	CEILING, LAY-IN	24
A2		2 LAMP F32T8 25W	STRIP LIGHT, (4-FOOT)	CEILING	43
A2e		2 LAMP F32T8 25W	STRIP LIGHT, (4-FOOT), (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	43
A4		4 LAMP F32T8 25W, TANDEM	STRIP LIGHT, (8-FOOT)	CEILING, LAY-IN	86
B		1 LAMP 9W CFL	CFL, RECESSED CAN OR SPOT LIGHT	CEILING	9
B1		1 LAMP 13W CFL	CFL, RECESSED CAN OR SPOT LIGHT	CEILING	13
B2		1 LAMP 15W CFL	CFL, RECESSED CAN OR SPOT LIGHT	CEILING	15
B2e		1 LAMP 15W CFL	CFL, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	15
B2fe		1 LAMP 15W CFL FLOOD	CFL FLOOD	CEILING, TRACK	15
B3f		1 LAMP 23W CFL FLOOD	CFL FLOOD	CEILING, TRACK	23
B4		1 LAMP 42W CFL	CFL	CEILING	42
B6		1 LAMP 26W CFL	CFL, RECESSED CAN OR SCREW-IN	CEILING	26
B6e		1 LAMP 26W CFL	CFL, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	26
B7		1 LAMP F42TBX CFL	BIAX CFL	CEILING	42
B8		2 LAMP 13W CFL	CFL, GENERAL AREA LIGHTING	CEILING	26
B8e		2 LAMP 13W CFL	CFL, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING OR WALL	26
B9e		2 LAMP 9W CFL	CFL, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	18
BP		1 LAMP 15W PAR38 CFL	CFL, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	15
C		2 LAMP F17T8	SURFACE WRAP	WALL	29
C1		1 LAMP F32T8 25W	SURFACE WRAP	WALL OR CEILING	24
C2		2 LAMP F32T8 25W	SURFACE WRAP	CEILING	43
C2e		2 LAMP F32T8 25W	SURFACE WRAP, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	43
C4		4 LAMP F32T8 25W	SURFACE WRAP	CEILING	86
C4e		4 LAMP F32T8 25W	SURFACE WRAP, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	86
CN2		2 LAMP F32T8 25W	SURFACE WRAP	CEILING	43
P2e		4 LAMP 26W CFL	SUSPENDED GENERAL AREA LIGHTING, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING/SUSPENDED	104
P4		4 LAMP F32T8 25W	PENDANT	CEILING	86
R2		2 LAMP F32T8 25W	RECESSED TROFFER	CEILING	43
R2e		2 LAMP F32T8 25W	RECESSED TROFFER, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	43
R3		3 LAMP F32T8 25W	RECESSED TROFFER	CEILING	67
R3e		3 LAMP F32T8 25W	RECESSED TROFFER, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	67
R4		4 LAMP F32T8 25W	RECESSED TROFFER	CEILING	86
R4e		4 LAMP F32T8 25W	RECESSED TROFFER, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	86
R6e		6 LAMP F32T8 25W	RECESSED TROFFER, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	132
U2e		2 LAMP F32T8 U-TUBE	2X2 LAY-IN, (LOCATED IN ZONES OF EGRESS AND/OR 24-HOUR SAFETY)	CEILING	59
W1e		1 LAMP F32T8 25W	WALL MOUNT	WALL	24
W2		2 LAMP F32T8 25W	WALL MOUNT	WALL	43
W4		4 LAMP F32T8 25W	WALL MOUNT	WALL	86
W6		4 LAMP F25T8	WALL MOUNT	WALL	82
X1		LED EXIT SIGN	EGRESS POINTS	WALL	5

LIGHTING CONTROL LEGEND			
SYMBOL	DESCRIPTION	MOUNTING	NOTES
	SWTCH, SINGLE POLE	WALL	-
	DUAL SWITCH	WALL	-
	THREE-WAY SWITCH	WALL	-
	CEILING-MOUNTED OCC. SENSOR	CEILING	30-MINUTE TIME DELAY SHUT-OFF
	WALL-MOUNTED OCC. SENSOR	WALL	30-MINUTE TIME DELAY SHUT-OFF
	WALL-MOUNTED DUAL RELAY OCC. SENSOR	WALL	30-MINUTE TIME DELAY SHUT-OFF

LINE LEGEND	
LINE	DESCRIPTION
	DAYLIGHT ZONE. AREAS WITHIN 15-FOOT RADIUS OF WINDOWS. THESE ZONES MAY NEED SPLIT CIRCUITRY AND SWITCHING TO SATISFY IECC CODE 505.2.2.3
	HATCHED AREAS ARE EXCLUDED FROM THE SCOPE OF WORK

