

ORDINANCE NO. 07-5426

AN ORDINANCE OF THE CITY OF BILLINGS, PROVIDING  
FOR THE REPEAL OF SECTION 14-301 AND REPLACING IT  
WITH A NEW SECTION 14-301; PROVIDING FOR THE  
ADOPTION OF THE 2006 EDITION OF THE INTERNATIONAL  
FIRE CODE AND CERTAIN AMENDMENTS

BE IT ORDAINED BY THE CITY COUNCIL OF THE CITY OF BILLINGS,  
MONTANA:

*Section 1.* That Section 14-301 of the Billings, Montana City Code entitled “Adoption by reference of the NFPA1/Uniform Fire Code and Administrative Rules,” is hereby repealed and declared null and void and of no effect.

*Section 2.* That the Billings, Montana City Code be amended by adding a new section 14-301, to read as follows:

**“Sec. 14-301. Adoption by reference of the 2006 edition of the International Fire Code**

- (a) The International Fire Code, 2006 edition, including Appendices B and C, as published by the International Code Council, is adopted by reference as the Fire Code of the City of Billings. It regulates and governs the safeguarding of life and property from fire and explosion hazards arising from the storage, handling and use of hazardous substances, materials and devices, and from conditions hazardous to life or property in the occupancy of buildings and premises as herein provided; provides for the issuance of permits and collection of fees therefore; and each and all of the regulations, provisions, penalties, conditions and terms of said Fire Code on file in the office of the Billings City Clerk are hereby referred to, adopted, and made a part hereof, as if fully set out, with the additions, insertions, deletions and changes, if any, set by ordinance.
- (b) The following sections of the Fire Code are revised as set out below:
  - Section 101.1. Insert: [City of Billings, Montana]
  - Section 109.3. Insert: [Misdemeanor, \$500.00, 6 months] so that such section shall read as follows:

**“Violation penalties.** Persons who shall violate a provision of this code or shall fail to comply with any of the requirements thereof or who shall erect, install, alter, repair or do work in violation of the approved construction documents or directive of the fire code official, or of a permit or certificate used under provisions of this code, shall be guilty of a misdemeanor, punishable by a fine of not more than \$500.00 or by imprisonment not exceeding 6 months, or both such fine and imprisonment. Each day that a violation continues after due notice has been served shall be deemed a separate offense.

Section 111.4. Insert: [not less than \$100 or more than \$500]

Section 906.1. Delete Exception to Section 906.1, #1.

“906.1 Where required.

Portable fire extinguishers shall be installed in the following locations.

1. In new and existing Group A, B, E, F, H, I, M, R-1, R-2, R-4 and S occupancies.

~~Exception: In new and existing Group A, B and E occupancies equipped throughout with quick-response sprinklers, portable fire extinguishers shall be required only in locations specified in Items 2 through 6.~~

2. Within 30 feet (9144 mm) of commercial cooking equipment.
3. In areas where flammable or combustible liquids are stored, used or dispensed.
4. On each floor of structures under construction, except Group R-3 occupancies, in accordance with Section 1415.1.
5. Where required by the sections indicated in Table 906.1.”

Section 907.15.1. When required by the Fire Code Official, non-required fire alarm systems shall be monitored by an approved supervising station in accordance with NFPA 72.

- (c) That the geographic limits referred to in certain sections of the 2006 *International Fire Code* are hereby established as follows:

**Section 3204.3.1.1 LOCATION.** Stationary containers shall be located in accordance with section 3203.6. Containers of cryogenic fluids shall not be located within diked areas containing other hazardous materials.

**Section 3404.2.9.5.1** Locations where above-ground tanks are prohibited. Storage of Class I and II liquids in above-ground tanks outside of buildings is prohibited within the limits established by the City of Billings and Yellowstone County Unified Zoning Regulations.

**Section 3406.2.4.4** Locations where above-ground tanks are prohibited. Storage of Class I and II liquids in above-ground tanks outside of buildings is prohibited within the limits established by the City of Billings and Yellowstone County Unified Zoning Regulations.

**Section 3804.2** Locations where the storage of liquefied petroleum gas is restricted for the protection of heavily populated or congested areas. Storage of liquified petroleum gas in above-ground tanks outside of buildings is prohibited within the limits established by the City of Billings and Yellowstone County Unified Zoning Regulations.

**Section 3. EFFECTIVE DATE.** This ordinance shall be effective thirty (30) days after second reading and final adoption as provided by law.

3